



Submitted to  
Brayton Point Energy, LLC  
1 Brayton Point Rd.,  
Somerset, MA 02725

Submitted by  
AECOM  
1001 Highlands Plaza Drive West  
Suite 300  
St. Louis, MO 63110

October 2016

# CCR Rule Report: Initial Structural Stability Assessment

For

Ash Basin C

At Brayton Point Power Station

This Coal Combustion Residual (CCR) Rule Report documents that Ash Basin C at the Brayton Point Energy, LLC Brayton Point Power Station is exempt from the structural stability assessment requirements specified in 40 Code of Federal Regulations (CFR) §257.73(d). Ash Basin C is located near Somerset, Massachusetts in Bristol County, approximately 0.2 miles northeast of the Brayton Point Power Station, in an area known as the Ash Basin Complex.

Ash Basin C is an incised CCR surface impoundment, as defined by 40 CFR §257.53, that is used to manage bottom ash discharge water. Under 40 CFR §257.73(b) a structural stability assessment (§257.73(d)) must be performed for an existing CCR surface impoundment that either:

- 1. Has a height of five feet or more and a storage volume of 20 acre-feet or more; or*
- 2. Has a height of 20 feet or more.*

Ash Basin C does not satisfy either of these criteria because the incised basin does not have dikes. Therefore, the Ash Basin C is not subject to the §257.73(d) structural stability assessment requirements.

## About AECOM

AECOM (NYSE: ACM) is a global provider of professional technical and management support services to a broad range of markets, including transportation, facilities, environmental, energy, water and government. With nearly 100,000 employees around the world, AECOM is a leader in all of the key markets that it serves. AECOM provides a blend of global reach, local knowledge, innovation, and collaborative technical excellence in delivering solutions that enhance and sustain the world's built, natural, and social environments. A Fortune 500 company, AECOM serves clients in more than 100 countries and has annual revenue in excess of \$19 billion.

More information on AECOM and its services can be found at [www.aecom.com](http://www.aecom.com).

1001 Highlands Plaza Drive West  
Suite 300  
St. Louis, MO 63110  
1-314-429-0100